



Telephone :- 25501000
PUNE MUNICIPAL CORPORATION
SHIVAJINAGAR, PUNE - 5.
OFFICE OF THE CHIEF FIRE OFFICER
CENTRAL FIRE STATION,
MAHATMA PHULE PETH,
PUNE - 411 042.
Outward No. 236
Date :- 8/4/2024

To,

M/s. Helios International School
S.No.7/1B/27B, Sun City Road,
Anand Nagar, Wadgaon Bk.,
Pune.

Sub:- Fire Safety Compliance for your school building.

Ref.:- Your letter Dated 04.04.2024

Dear Sir,

With reference to letter under reference above this is to inform you that, the M/s. Helios International School on S.No.7/1B/27B, Sun City road, Anand Nagar, Wadgaon Bk., Tal.Haveli, Dist.Pune. have complied with the fire prevention & fire safety requirement in accordance with NBC-2016 for Educational Building. However at present construction is done up to G + 06 building. Now proposed occupancy for school is upto G + 06 Floor. Annual Fee is paid by challan No.7035 , Dt.06.04.2024, Rs.4,600/-

Please ensure that the system provided for the protection of the school building should be maintained properly & regularly and certificate issued from the licensed agency should be submitted in the letter to this office on January & June every year.

1. The scope of this letter is restricted to fire protection arrangements only. This letter should not be treated / presumed as an approval for civil / architectural drawings.
2. The area calculation statements TDR/FSI/FAR etc shall be subject to verification and letter of PMC competent Authority.
3. The required Marginal Open spaces as per UDCPR requirements mentioned in Regulation 15.1 kept open and obstruction free at all time.

This letter is issued considering the request of M/s. Helios International School for submission to the CBSE Board Authorities.

Thanking you,



Prabhakar S. Umratkar
08/04/2024
(Prabhakar S. Umratkar)
Station Duty Officer
Pune Municipal Corporation

SARASWATIDEVI RAMCHANDRA MITTAL FOUNDATION
 Site – Helios International School, S.NO.7/1B/27B, WADGAON (BK), PUNE.

INSPECTION REPORT WITH ACTIVE FIRE FIGHTING SYSTEM FOR COMMERCIAL BLD

Sr. No.	Description	Riser 1	Riser 2
1	6" Dia Riser, GI C Class Pipe	1 nos	1 nos
2	Booster Pump 900 LPM	1 nos	1 nos
3	DOL Starter for Booster Pump	1 nos	1 nos
4	Butterfly Valve 150 mm for Riser	1 nos	1 nos
5	Butterfly Valve 100 mm for Booster Pump	1 nos	1 nos
6	NRV 100 mm for booster pump	1 nos	1 nos
7	Hose Box	7+4	7+4
8	Hose Pipe	7+4	7+4
9	Branch Pipe	7+4	7+4
10	Hydrant Valve	7+4	7+4
11	Fire Hose Reel with Rubber Hose Pipe	7 nos	7 nos
12	Service Inlet	Provided	
13	Main Fire Pump 2250 LPM -2 Nos	Provided	
14	Jockey Pump 180 LPM - 1 Nos	Provided	
15	Main Fire Pump Control Panel	Provided	
16	ABC Type Fire Extinguisher 4 kg	14 nos	
17	CO2 Type Fire Extinguisher 4.5 kg	1 nos	
18	Sprinkler System provided in Basement Floor	Provided	
19	PA System	Provided	

The above installation has been tested and is found in good working condition. The installation has been demonstrated to the concerned owner to his satisfaction and has been handed over to him as mentioned above in all aspects

For- **Sumeet Fire Engineers Pvt. Ltd.**





SFEPL - 002 /25-26

FORM B

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely*: -

SARASWATIDEVI RAMCHANDRA MITTAL FOUNDATION
Site – Helios International School, S.NO.7/1B/27B, WADGAON (BK), PUNE.

I/We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period **01/01/2025 To 30/06/2025** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah, III of 2007). The details of the inspection of installation carried out by me/us are mentioned in the report appended herewith.



Place: Pune

Date: 30/05/2025


Sumeet Fire Engineers Pvt. Ltd.

Rajmohan Apartment, 3rd Floor, 34/2, 35/2, Karve

Road, Garware Collage Metro Station, Pune

License No: - MFS/LA/RF-137/RD-131/RP-43

Govt. of Maharashtra



3459

2025/05/30